

11. Corrosion

Reference should be made to the attached "Pipe Culvert Material Alternates" chart for materials allowable by the Laboratory corrosion test.

12. Bench Detail

Where new fills are to be placed on existing slopes steeper than 3:1, the existing slope should be benched in accordance with the attached detail.

13. Special Problems

A. Several residences are located very close to the construction limits of this project. Vibrations from construction may cause some concern with property owners. We recommend that the Project Engineer contact the Geotechnical Engineering Bureau prior to construction to evaluate the need for crack surveys.

B. We recommend that all bridge approach slabs on this project be constructed in accordance with the notched detail on Georgia Standard 9017-R.

Reported By:

Yong Shao, PhD, PE

