

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Coleman Road Lift Station Pump

DATE OF MEETING: September 8, 2015

BUDGET IMPACT: \$35,144.20

FUNDING SOURCE

Annual

Capital

N/A

Regular Meeting

Work Session

Recommendation

Policy/Discussion

Report

Other

COUNTY ACTION REQUESTED ON: Coleman Road Lift Station Pump

HISTORY, FACTS AND ISSUES: The Coleman Road lift station is a duplex station that is currently running on one pump. The pump that is out of service is a Flygt pump that was built in 1995. Staff received a quote to have to pump repaired for \$32,554.90. Two additional quotes were received for a new Flygt pump for \$69,755.00 and a new Wilo pump for \$35,144.20. After considerable research staff recommends the purchase of the Wilo pump at the Coleman Road lift station.


OPTIONS: (1) Approve the purchase of Wilo pump
(2) Board's Pleasure

RECOMMENDED ACTION: Approve the purchase of Wilo pump

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____