

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Peterson Road Lift Station Pump

Work Session/Regular Session

DATE OF MEETING: August 27, 2019

BUDGET IMPACT: \$29,689.20

FUNDING SOURCE:

- Annual
- Capital
- N/A
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: Peterson Road Lift Station Pump

HISTORY, FACTS AND ISSUES: The Peterson Road lift station received lightening damage on August 1, 2019, that rendered pump number two inoperable. The pump was sent to Xylem for repairs. The cost to repair the pump is \$29,689.20, and the cost of a new pump is \$70,577.00. Staff recommends the pump be repaired by Xylem for \$29,689.20.

OPTIONS: 1. Approve
2. Board Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities

DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: