

1.04**SITE INVESTIGATION**

- A. Potential Contractors shall visit the project site prior to bid date to satisfy themselves as to the existing conditions and distances which may effect the cost of the project. Where work under this project requires extension, relocation, re-connecting or modifications to existing equipment or systems, the existing equipment or systems, shall be restored to their original condition, with the exception of the work under this contract, before the completion of this project.

1.05**SHOP DRAWINGS**

- A. Submit for approval by the Engineer all materials and equipment to be incorporated in the electrical work.
- B. Submit only shop drawings which comply with the contract documents. Shop drawings shall be checked and corrected by the Contractor before they are submitted to the Engineer. Shop drawings that are not corrected by the Contractor shall be returned for correction without detailed notations by the Engineer as to the necessary corrections.
- C. Mark each individual submittal item to show specification section which pertains to the item.
- D. Submit information as required under SUBMITTALS, for each of the individual electrical sections of the specifications.
- E. Data submitted shall contain all information required to indicate compliance with equipment specified.
- F. Submit field information drawings to explain fully all procedures involved in erecting, mounting and connecting all items of equipment which differ from that specified.
- G. When Shop Drawings are reviewed, some errors may be detected but others may be overlooked. This does not grant the Contractor permission to proceed in error. Regardless of any information contained in the Shop Drawings, the requirements of the Drawings and Specifications shall be followed and are not waived or superseded in any way by the Shop Drawing review.

1.06**RECORD DRAWINGS:**

- A. One complete set of electrical drawings shall be reserved for as-built drawings. Any approved deviation from the contract drawings shall be recorded on these drawings.
- B. Completed as-built drawings shall be presented to the Engineer prior to final inspection.