



Phone (229) 244-1967

Fax (229) 247-3245

119 Blanchard Street • Valdosta, Georgia 31601
www.rpiunderground.com

Change Order

June 9, 2021
Attn: Steve Stalvey
Re: Bemiss Low Pressure Sewer Main Replacement

Steve,

We have the hdpe and 12 inch casing/casing spacer numbers. With the 140 lf 12 inch steel casing installed by jack-n-bore, flagger, additional 200 lf 8 inch dr 11 hdpe in leu of 6 inch, upsizing the valves and fitting for future connection, additional costs will be \$33,989.00. Call me with any questions or clarifications. Thanks

TOTAL: \$ 33,989.00

If you have any questions, please feel free to call me at the above number.

Sincerely,

Kenneth Thatcher

Kenneth Thatcher
President

*Underground Utility Contractor License # GA UC302394
Underground Utility Contractor License # FL CUC1225469*