



**Lowndes County Engineering Department**

---

**To:** *Prospective Bidders on #ENG 2022-01: Griner Park*  
**From:** *Chad McLeod*  
**Subject:** *Addendum No. 2*  
**Date:** *August 12, 2022*  
**CC:** *Amy Woods, Walt Deloach, Terry McEntyre*

---

1. **Addendum # 2 must be dated and noted on the addenda sheet and turned in with bids.**
2. **The new bid date is September 6, 2022 @ 10:00.**
3. **On revised sheet C3.0 you will find the Phase line as discussed in the prebid meeting. The bid is for Phase I & II. Phase I will need to be completed before starting on Phase II.**
4. **The contract completion time has been changed from the completion date of November 11, 2022 to 270 calendar days. The new contract time is 270 calendar days.**
5. **On sheet C6.0, please see the pipe bedding detail. The boxes will also need to be bedded.**

Questions and Answers. All Answers are in **bold** letters.

1. Details for brick column footers and columns? **Please see attached details.**
2. Brick selection and cast stone color? **Lowndes County has the brick. Stone color will match Judicial Building stone.**
3. Are the gates to be swing or slide? **Slide**
4. Is there a particular manufacturer for removable bollards? **No**
5. Sheet C2.0 – How thick is the existing asphalt millings parking lot? There is a note on this sheet that says to use this as the base for the proposed