



Superior Metal Buildings, Inc

6125 Union Rd.
 Hahira, GA 31632
 Phone: (229) 585-9396

JOB / QUOTE #: **AS1463**

BLDG#: #1

DATE: 2/26/2025



ACCREDITED
AC472

CUSTOMER & PROJECT INFORMATION:										
CUSTOMER: SUPERIOR METAL BUILDINGS				JOBSITE:				DRAWINGS:		
ADDRESS: 6125 UNION RD. HAHIRA, GA. 31632				ADDRESS: VALDOSTA, GA 31603				ADDRESS:		
CONTACT: STACY STUBBS				EMAIL:						
PHONE:										
DESIGN LOADS & BUILDING CODES:										
MBM makes no claims or representation as to the accuracy of Environmental Loads on Buildings. It is Customer/ End User's responsibility to check Local Building Department requirements.										
BLDG OCCUPANCY/RISK CAT: II - Normal				DEAD LOAD(psf) : 2.00						
BUILDING CODE: GSBC 20 (IBC 18)				ROOF LIVE LOAD(psf) : 20.00			LL REDUCTION: Yes			
WIND SPEED:(mph) 113				COLLATERAL LOAD(psf) : 1.00			SITE CLASS : d			
ENCLOSURE TYPE: OPEN Exp: B				SEISMIC COEF(Ss) : 0.0921			DESIGN CAT: B			
GROUND SNOW LOAD:(psf) 0.00				SEISMIC COEF(S1) : 0.0552			DEFLECTION: STANDARD			
ROOF SNOW LOAD:(psf) 0.00				<i>10 Year Design wind loads used for Serviceability</i>						
FRAMING COLORS:		PRIMARY : RED OXIDE			SECONDARY:			RED OXIDE		
BUILDING SPECIFICATION:										
TYPE:	WIDTH:	LENGTH:	BSW HT.:	FSW HT.:	PEAK OFFSET:	ROOF PITCH:	BAY SPACING:	LEW SPACING:	REW SPACING:	
CS	30	40	12	12	15	1.000:12	2 at 20	1 at 30	1 at 30	
ENDWALL TYPE:			LEFT ENDWALL: NONE			RIGHT ENDWALL: NON-EXPANDABLE				
GIRT CONDITION:					WALL BRACING:					
FRONT SIDEWALL: BYPASS		LEFT ENDWALL: FLUSH		FRONT SIDEWALL: WIND COLUMN			LEFT ENDWALL: NONE			
BACK SIDEWALL: BYPASS		RIGHT ENDWALL: FLUSH		BACK SIDEWALL: WIND COLUMN			RIGHT ENDWALL: NON-EXPANDABLE Frame			
RIGID FRAME:										
TYPE:	TRIB WIDTH (FT):	INT CO. LOC(ft):	FRAME LINE:	TYPE:	TRIB WIDTH(FT):	INT. CO.LOC(ft):	FRAME LINE:			
RF-	24.39		2							
RF-	10.5		3							
PANELS:	TYPE:	GA:	COLOR:	INSULATION:	FAST. TYPE:	FAST. LGTH:	EAVE CONDITION:			
ROOF:	PBR	26	GALVALUME	NONE	LL ZAC	1-1/4"	GUTTER W/EAVE	FSW:	BSW:	
WALLS:							GUTTER(FT)	42	42	
BASE COND:							DOWN(SQNTY)	INC	INC	
FRAMED OPENING:										
LEW:	NONE				FSW:	NONE				
REW:	NONE				BSW:	NONE				
ACCESSORIES INCLUDED:										
1	GA ENGINEER STRUCTURAL STAMP									
NOTES:										
ALL WALLS OPEN FULL HEIGHT TO REMAIN 8" PERLINS IN ROOF 5'-0" O.C. PURLINS EXTENDED 2' @ LEW FOR LAPPING ONTO EXISTING BUILDING BY OTHERS HSB NOT RESPONSIBLE FOR ANY LOADS OR ATTACHMENT TO EXISTING BUILDING										
Jobs ordered on approval or permit status are subject to re-pricing, when released for fabrication.										